Scott. II-27—40,000—14-10-38.

P. W. (1938) Department.

hrs SERIES.

G.O. No.	2225
Dated	17 · X · 38

[Despatch Abstract.]

Electric installation — South Kanara, Mangalore — Decarlos of the bill type of Pole Expire — Rs 3380

Approved

POLICE DEPARTMENT.

Subject.

Electrification - District Superintendent's quarters, Mangalore - Plans and Estimate - Submitted.

Re No. 1014/H3/38

Station. M a d r a s, Dated the 28 August 1938.

From

F. Sayers, Esquire, C.I.E.,
Inspector-General of Police, Madras.

To

The Secretary to the Government of Madras,
Home Department.

Sir,

I have the honour to submit for the approval of the Government, plans and an estimate amounting to Rs.3,500/- for the electrification of the residence of the District Superintendent of Police, South Kanara at Mangalore which is now under construction. It would be convenient, I suggest, for this work to be carried out whilst the building is under construction and, if approved, the Chief Engineer will be asked to provide funds for it in the Civil Works Estimate for 1938-1939.

2. I also request that the Government will be pleased to sanction, under paragraph 126(b)(4) of the Public Works Account Code, the expenditure of Rs.3,500/- on this work from the lump sum grant for Police Minor Works in 1938-1939.

I have the honour to be,
Sir,
Your most obedient servant,

for Inspr.-Genl. of Police.

P.M.N./23-8-38.

Home (B) Dept.

Memo. No

Buildings South Kanara Dt
& Residence of the D.S.P. at
Mangalore - Electrification -
Ref:- I.G's letter Re No.
1014/H.B/38 dt 25.8.38

The I.G. of Police is requested to report (1) whether it is not possible to reduce by one the number of electric fans either in one of the Dressing rooms or in the Sitting room in the top floor of the D.S.P's residence at Mangalore and (2) whether the provision of wall plugs in the residence, except the one in Maley's room in the ground floor, may not be omitted.

2. The plans and estimates for the above work received with the I.G.'s letter are returned to him for correction if necessary.

4

53



POLICE DEPARTMENT.

29261

Subject.

Electrification - District Superintendent's quarters, Mangalore - Plans and Estimate - Submitted.

Re No. 1014/H3/38

Station. M a d r a s, Dated the 25 August 1938.

From

F. Sayers, Esquire, C.I.E.,
Inspector-General of Police, Madras.

To

The Secretary to the Government of Madras,
Home Department.

Sir,

I have the honour to submit for the approval of the Government, plans and an estimate amounting to Rs.3,500/- for the electrification of the residence of the District Superintendent of Police, South Kanara at Mangalore which is now under construction. It would be convenient, I suggest, for this work to be carried out whilst the building is under construction and, if approved, the Chief Engineer will be asked to provide funds for it in the Civil Works Estimate for 1938-1939.

2. I also request that the Government will be pleased to sanction, under paragraph 126(b)(4) of the Public Works Account Code, the expenditure of Rs.3,500/- on this work from the lump sum grant for Police Minor Works in 1938-1939.

I have the honour to be,
Sir,
Your most obedient servant,

for Inspr.-Genl. of Police.

P.M.N./23-8-38.

5/

C.No.29261
26-8-38

Home (B) Department

Buildings - South Kanara Dt.- D.S.Pa. residence-Mangalore - Electrification -

---

From the I.G. of Police, R.C.No.1014/H.B./38 dated 25-8-38,

The I.G. of Police proposes the electrification of the D.S.P.'s residence at Mangalore (which is now under construction) at an estimated cost of Rs.3,500/-. It is suggested that it would be convenient if the work is carried out whilst the building is under construction.

The proposal involves the provision of 38 lights, 11 fans and 10 wall plugs. The installation of 38 lights may be accepted.

Fans: Fans have been proposed in the two dining rooms in the ground floor - one in the 'Indian' Dining room and the other in the European Dining room. This may be allowed. The provision of fans in each of the dressing rooms and in the sitting room in the top floor seems excessive. One fan may be cut out.

Wall plugs: In connection with the electrification of the D.S.P.'s residence at Chittoor, the P.W. Dept. have pointed out that the provision of wall plugs is not necessary in rooms where lights and fans have been provided in big residences. No wall plug seems necessary in this residence except the one in the Matey's room in the ground floor. The remarks of the I.G. may be invited.

Draft memo. submitted. P.W.D. may see before issue.

2.9.38

The estimate seems rather lavish. P.W. should see before it is referred

¢ 6

back to the I.G.

8/9

8/9

Home 2926 IB



P.W.D.

A provisional data statement for calculating rent ~~after the installation~~ ~~of lifts~~ has not been submitted. A revised estimate of Rs 40,000 for the work ~~sanctioned~~ ~~of~~ of constructing quarters for the D.S.P. was approved in ~~G.O.~~ No. 2310 P.W./4.2.37 and the work is stated to be in progress. Of the amount mentioned above only about Rs 28,000 is the estimated cost of building ~~or~~ outhouses. If to this, the estimated cost of electric installation is added the capital cost on which rent ~~will be~~ calculated comes up to Rs 31,500. The standard rent will therefore be about Rs 158. The average pay of a D.S.P. is Rs 1000 under the old scale of pay and Rs 873 in the new scales of pay. The standard rent will not therefore be realised. But as the D.S.P. is a high official the proposal to electrify his residence may be approved.

The Home Deptt remark that the provision

(X) 'A' on p 1 of

which is in p 16 of G.O. at (X),

~~Rs 28,000~~
~~Rs 3,500~~
Rs 31,500

= 1/12 of 6 % of Rs 3,500 = Rs 157½

of fans in each of the dining rooms and in the sitting room in the top floor second extension. It is submitted that the standard scale of electric fittings for Govt. residences approved in Govt. No. 112 PW 3/20/38 allows one (or two in the case of big rooms) large size fan in each of the sitting rooms and one small or baby size fan in each of the dining rooms. The provision proposed in this case is in accordance with the standard scale and may be allowed.

B on plan

T

Recd 6/10

The estimate includes provision for 10 wall plugs, all of them are proposed in Matey room, being proposed in rooms where lights and fans have been proposed. As mentioned by the Hon. Dipty. Ar. in the plan, it is usual to cut out the ~~the dipty. has been usually without~~ provision for wall plugs in rooms not having lights and fans. In regards the Matey room it is observed that while there is no light or fan according to the standard scale no fan is allowed for the Matey room and there is already a light in it, there is no necessity to allow a wall plug in this room also, and as the provision for wall plugs may be omitted altogether. It is

Type 2-4 CP and plans put up.

With plan at (Y)

(T)

The Exy. & Police asks for sanction t

8
*

execute the work in the current year from [illegible] the lump sum grant for Police Minor Works.

As however the work of construction of the residence is in progress it is submitted. Monies that the present estimate may be sanctioned as supplemental to the estimate for the construction of the residence

A draft order is submitted for consideration It may be sent to Home & Finance for acceptance

5.10.38 5/10

6/10

8/10

Home

Fin

P.W.D. 4010 40?-1

7.X.38.

7-OCT 1938

Home (B) Dept.

[Previous note of this Dept. on pp. 1-2 ante]

In the circumstances stated in para 3 above it is submitted that the draft order may be accepted and the file passed on to Finance.

ASST SECRETARY TO GOVT. C 15 OCT 1938 4693 PUBLIC WORKS DEPARTMENT

10.10.38 8/10

Home 3243 B-1 187+38

Fin

Finance (Sp.)

The draft order may be accepted and the case returned to the PWD.

12.X.38 12.X.38

13.10.38 18.10.38

ASSISTANT SECRETARY TO GOVERNMENT 10 OCT 1938 FINANCE DEPT.

P.W.D.

Trillo 35145 14.10.38